

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 11 of EN 13501-1:2018, December of 2018.

4.2 Classification

The product, L'FLOOR CARPET WHITE BIO, in relation to its reaction to fire behaviour is classified :

B fl

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

Without additional classification

The format of the reaction to fire classification for floorings is:

Fire behaviour			Smoke Production
B fl	-	s	1

i.e., **B fl - s1**

Reaction to fire classification:

B fl - s1

4.3 Field of application

This classification is valid for the following product parameters:

- Nominal thickness: 2 mm
- Density: 500 kg/m³
- Weight / unit area: 1000 g/m²
- Colour: white

The classification is valid for the following end use applications:

- product applied on class A1 and A2-s1,d0 substrates, simply in contact (EN 13238:2010)

ETE211/22

Notes: The presented results refer exclusively to the tested specimens and apply to the sample as received.

Data reported with (*) was supplied by the customer, who has the sole responsibility for the accuracy of the information.

This report may not be reproduced, except if complete, without the written consent of Itecons.